



Corporate Hazard Identification & Risk Control

HIRA #
15.23

Fall Protection

Applicable Zones:	Project	<input checked="" type="checkbox"/>	Yard	<input checked="" type="checkbox"/>	Office		Asphalt Plant	<input checked="" type="checkbox"/>
--------------------------	---------	-------------------------------------	------	-------------------------------------	--------	--	---------------	-------------------------------------

HAZARD(S)

- Fall from heights (P)
- Suspension Trauma (P)
- Equipment Failure (P)

PRE-CONTROL RISK

Likelihood 2	Consequence 3	Pre-Control Risk 6
-----------------	------------------	-------------------------------

CONTROLS

Elimination	If equipment can be used to complete the elevated task then do so.
Substitution	
Engineering	Always inspect all components of your fall prevention or arrest system before use. Anchors must meet or exceed the requirements found in O.Reg 213/91 S.26
Administrative	Consult J-AARs SWP for Working at Heights
PPE	Workers must be tied off 100% of the time while exposed to a fall of greater than 10 feet. High Visibility Clothing, Hard Hat & Safety Boots at a minimum must be worn at all times.

POST CONTROL RISK

Likelihood 2	Consequence 2	Post-Control Risk 4	Risk Reduction 2	Critical or Not Critical No
-----------------	------------------	--------------------------------	---------------------	-----------------------------------

LEGISLATIVE REFERENCES

O.Reg 213/91: S26-26.9
 O.Reg 213/91: S33
 O.Reg 213/91: S129
 O.Reg 213/91: S138.2
 O.Reg 213/91: S142.06
 O.Reg 213/91: S142.7
 O.Reg 213/91: S153.2
 O.Reg 213/91: S247.1.c

OTHER STANDARDS & REFERENCES

J-AAR Manual – P1.3.2
 J-AAR Manual – P2.4.11
 J-AAR Manual – P2.11.11
 J-AAR Manual – P2.12.11.11
 J-AAR Manual – P2.12.11.12