



Corporate Hazard Identification & Risk Control

HIRA #
15.38

Lack of Documentation (Locates)

Applicable Zones:	Project		Yard		Office		Asphalt Plant	
--------------------------	---------	--	------	--	--------	--	---------------	--

HAZARD(S)

- Utility Strike (P)
- Inhalation Hazard (H)
- Electrical Hazard (P)
- Struck By Injury (P)

PRE-CONTROL RISK

Likelihood 3	Consequence 5	Pre-Control Risk 15
-----------------	------------------	--------------------------------

CONTROLS

Elimination	Ensure Valid locates are available and work is taking place within the located area.
Substitution	
Engineering	Mark while working. Continually checking on buried lines and locates.
Administrative	Dig within 1m to daylight lines to avoid striking them.
PPE	High Visibility Clothing, Hard Hat & Safety Boots at a minimum must be worn at all times.

POST CONTROL RISK

Likelihood 2	Consequence 5	Post-Control Risk 10	Risk Reduction 5	Critical or Not Critical Yes
-----------------	------------------	---------------------------------	---------------------	---------------------------------

LEGISLATIVE REFERENCES

O.Reg 213/91: S. 181-195.3
O.Reg 213/91: S. 222-242

OTHER STANDARDS & REFERENCES

J-AAR Manual: P2.11.4
J-AAR Manual: P2.11.5
J-AAR Manual: P2.12.11.4
J-AAR Manual: P2.12.11.4