



Corporate Hazard Identification & Risk Control

HIRA #
15.48

Mobilization

Applicable Zones:	Project	X	Yard		Office		Asphalt Plant	
--------------------------	---------	--------------	------	--	--------	--	---------------	--

HAZARD(S)

- Negligent Contractor (P & H)
- Property or Utility Damage (no valid locates) (P)
- Electrical Hazard (temp. overhead lines not clearly marked or communicated) (P)

PRE-CONTROL RISK

Likelihood 3	Consequence 5	Pre-Control Risk 15
-----------------	------------------	--------------------------------

CONTROLS

Elimination	All workers are to attend a site-specific orientation by the contractor which covers general site specific hazards, material storage plans, traffic control plans and emergency plans. (and where facilities are located)
Substitution	
Engineering	
Administrative	Daily JHA's are to be completed and communicated with the workers by a competent supervisor to communicate any actual or potential hazard workers may come across.
PPE	High Visibility Clothing, Hard Hat & Safety Boots at a minimum must be worn at all times.

POST CONTROL RISK

Likelihood 1	Consequence 5	Post-Control Risk 5	Risk Reduction 10	Critical or Not Critical No
-----------------	------------------	--------------------------------	----------------------	--------------------------------

LEGISLATIVE REFERENCES

O.Reg. 213/91: S. 17
O.Reg. 213/91: S. 29
O.Reg. 213/91: S. 69.1
O.H.S.A.: S. 25(2)
O.H.S.A.: S. 51-53

OTHER STANDARDS & REFERENCES

J-AAR Manual
P1.4.18 P1.5.4.18
P2.11.8 P2.12.11.8
P2.11.9 P2.12.11.9