



Corporate Hazard Identification & Risk Control

HIRA #
15.75

Working at Heights

Applicable Zones:	Project	X	Yard		Office		Asphalt Plant	
--------------------------	---------	--------------	------	--	--------	--	---------------	--

HAZARD(S)

- Fall from heights (P)
- Suspension Trauma (P)
- Equipment Failure (P)

PRE-CONTROL RISK

Likelihood 4	Consequence 5	Pre-Control Risk 20
-----------------	------------------	--------------------------------

CONTROLS

Elimination	Can the work or working area be moved to ground level so that the need to work from heights is removed.
Substitution	If there are tools or equipment that can complete work at heights then do so.
Engineering	Always inspect all components of your fall prevention or arrest system before use. Anchors must meet or exceed the requirements found in O.Reg 213/91 S.26
Administrative	Working at Heights policy and procedure needs to be followed at all times.
PPE	High Visibility Clothing, Hard Hat & Safety Boots at a minimum must be always worn.

POST CONTROL RISK

Likelihood 2	Consequence 5	Post-Control Risk 10	Risk Reduction 10	Critical or Not Critical Yes
-----------------	------------------	---------------------------------	----------------------	------------------------------------

LEGISLATIVE REFERENCES

O.Reg 213/91: S26-26.9
 O.Reg 213/91: S33
 O.Reg 213/91: S129
 O.Reg 213/91: S138.2
 O.Reg 213/91: S142.06
 O.Reg 213/91: S142.7
 O.Reg 213/91: S153.2
 O.Reg 213/91: S247.1.c

OTHER STANDARDS & REFERENCES

J-AAR Manual – P1.3.2
 J-AAR Manual – P2.4.11
 J-AAR Manual – P2.11.11
 J-AAR Manual – P2.12.11.11
 J-AAR Manual – P2.12.11.12